



# RxMS Tech Notes

12/14/2018

Site Certified ®

## Customer Information

Bob Thomas  
Rx Monitoring Services, Inc.  
22A Eastman Ave  
Bedford, NH 03110, US  
603-930-3316

Rx Site #: 31098  
Monitor S/N: 40446

## Site Information

Demo  
22a Eastman Ave  
Bedford, NH 03110, US

Client Site Code:  
Site Equipment:  
Monitor Location: Output

## Comments:

Frequent surges on L3 and high voltage (530 VAC) indicate that the power conditioner is malfunctioning and requires service. The voltage angle was 121 degrees and flat-topped phase-ground voltage waveforms point to a possible ground reference issue. Also, there were utility based low-frequency PFC events at 5:51AM daily. The power conditioner needs immediate repair and service to correct the surge events and high voltage conditions. Make sure that the system is properly grounded by checking all ground connections and tightening as necessary. Make sure that there is a full size ground wire running from the system directly to building steel. Note that utility based PFC events with multiple zero-crossings and momentary over voltages will degrade and damage system components. To prevent potential damage from PFC events consider upgrading the protection level to that of an on-line UPS. If there are questions about the data in this report contact RxMS.

This power quality survey was conducted by an independent power and environmental consulting firm, Rx Monitoring Services, Inc. (RxMS). The equipment used to perform the survey was provided by RxMS and calibrated prior to shipment and again upon return according to our internal procedures and national standards.

The client is only responsible for the installation of the equipment and has either no or limited access to the data. The data gathered at the site is compared to the original equipment's site specification guideline (supplied at the initial installation) and used to provide the recommendations found in the report. For technical assistance please contact, at no extra charge, Rx Tech Support at 1-603-666-6606. RxMS is not affiliated with any power conditioning manufacturer or distributor but will refer solutions for your convenience if no local source is available.

**Rx Monitoring Services, Inc.**

**22A Eastman Ave.  
Bedford, NH. 03110**

**www.rxms.com  
1-888-329-2321**



# Executive Summary

12/14/2018

Rx Monitoring Services, Inc. - Demo

11/14/2018 - 11/28/2018

Site Certified ®

## Customer Information

Bob Thomas  
Rx Monitoring Services, Inc.  
22A Eastman Ave  
Bedford, NH 03110, US  
603-930-3316

## Site Information

Demo  
22a Eastman Ave  
Bedford, NH 03110, US

Rx Site #: 31098

Monitor S/N: 40446

Client Site Code:

Site Equipment:

Equipment Age:

Monitor Location: Output

| Power Quality  | Chan L1-L2 | Chan L3-L1 | Chan L2-L3 | Chan L1-G | Rx Rating | Meets Specs | Comments                           |
|----------------|------------|------------|------------|-----------|-----------|-------------|------------------------------------|
| Power Failures | 0          | 0          | 0          | 0         | Good      | Yes         |                                    |
| Sags           | 0          | 1          | 1          | 0         | Minor     | No          | Unusual: Cond. may need adjustment |
| Surges         | 0          | 34         | 35         | 0         | Minor     | No          | Power Conditioner needs repair     |
| Transients     | 0          | 0          | 0          | 0         | Good      | Yes         |                                    |
| Impedance mΩ   | N/A        | N/A        | N/A        | N/A       |           |             |                                    |

| Data Logging    | Actual Low | Actual High | Low Spec | High Spec | Rx Rating | Meets Specs | Comments                            |
|-----------------|------------|-------------|----------|-----------|-----------|-------------|-------------------------------------|
| Chan L1-L2      | 467        | 509         | 456      | 504       | Minor     | No          | Momentary Sags                      |
| Chan L3-L1      | 472        | 532         | 456      | 504       | Moderate  | No          | Momentary surges                    |
| Chan L2-L3      | 467        | 532         | 456      | 504       | Moderate  | No          | Repair/Adjust Conditioner           |
| Chan L1-G       | 269        | 295         | 263      | 291       | Minor     | No          | Possible PFC: remove PFC or add UPS |
| Frequency       | 59.8       | 60.2        | 59.0     | 61.0      | Good      | Yes         | Within Spec.                        |
| Max V Imbalance | N/A        | 2.9%        | N/A      | 3.0%      | Good      | Yes         | Within Spec.                        |
| Temperature °F  | 69         | 73          | 60       | 80        | Good      | Yes         | Within Spec.                        |
| Humidity        | 24         | 58          | 15       | 80        | Good      | Yes         | Within Spec.                        |
| L1 Current      | 3.6        | 95.4        | N/A      | N/A       | N/A       | N/A         | L1 Current Peak RMS                 |
| L2 Current      | N/A        | 91.1        | N/A      | N/A       | N/A       | N/A         | L2 Current Peak RMS                 |
| L3 Current      | N/A        | 88.3        | N/A      | N/A       | N/A       | N/A         | L3 Current Peak RMS                 |
| Neutral         | 3.0        | 58.8        | N/A      | N/A       | N/A       | N/A         | Neutral Peak Current                |
| Ground          | N/A        | 0.0         | N/A      | N/A       | N/A       | N/A         | Not connected                       |
| DC Volts - CH 1 |            |             |          |           |           |             |                                     |
| DC Volts - CH 2 |            |             |          |           |           |             |                                     |

## Rx Ratings

| Safety                               | Severe                                        | Moderate                                 | Minor                                   | Good                               |
|--------------------------------------|-----------------------------------------------|------------------------------------------|-----------------------------------------|------------------------------------|
| NEC Violation or other Safety Hazard | Damage is likely. Disruption is Highly likely | Damage is possible. Disruption is likely | Damage unlikely. Disruption is possible | Within Manufacturer Specifications |

Please email [Sales@rxms.com](mailto:Sales@rxms.com) or call Rx Monitoring Services, Inc. at (603) 666-6606

for answers to any questions regarding this report.

Bedford, NH. USA - [WWW.RXMS.COM](http://WWW.RXMS.COM)



12/14/2018


## Sags-Surges vs. Duration

Site: 31098

Rx Monitoring Services, Inc. Demo

11/14/2018 - 11/28/2018

☐ Filter Good Events



### Recommendations:

All sags are related to equipment use (step load and pulsing load) and output impedance / response time of power conditioner. Power conditioner or UPS may be undersized, improperly applied, or malfunctioning.



12/14/2018


## Transient (Additive/Subtractive)

Site: 31098

Rx Monitoring Services, Inc. Demo

11/14/2018 - 11/28/2018

☐ Filter Good Events



### Recommendations:

Daily PFC capacitor impulses @5:51AM (as well as other times) and a number of minor subtractive impulses, possibly related to load switch-on: this requires that additional power protection be added.



# Detailed Event Log

12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

☒ Filter Good Events

11/14/2018 - 11/28/2018

| Date/Time               | Event ID | Event Type      | Chan  | P 1 | P 2    | P3  | Severity |
|-------------------------|----------|-----------------|-------|-----|--------|-----|----------|
| Nov 14, 18 18:08:17     | 177      | System Power-Up |       |     |        |     |          |
| Nov 14, 18 18:08:19     | 178      | Start           |       |     |        |     |          |
| Nov 14, 18 20:09:00.544 | 294      | RMS Surge       | L3-L1 | 529 | 358    | 493 | Minor    |
| Nov 14, 18 20:09:00.544 | 293      | RMS Surge       | L2-L3 | 530 | 358    | 495 | Minor    |
| Nov 15, 18 02:23:40.478 | 299      | RMS Surge       | L3-L1 | 531 | 225    | 496 | Minor    |
| Nov 15, 18 02:23:40.478 | 298      | RMS Surge       | L2-L3 | 531 | 225    | 495 | Minor    |
| Nov 15, 18 02:44:46.219 | 309      | RMS Surge       | L3-L1 | 532 | 76533  | 496 | Minor    |
| Nov 15, 18 02:44:46.219 | 310      | RMS Surge       | L2-L3 | 532 | 76533  | 495 | Minor    |
| Nov 15, 18 02:59:00.611 | 315      | RMS Surge       | L3-L1 | 530 | 800    | 495 | Minor    |
| Nov 15, 18 02:59:00.611 | 314      | RMS Surge       | L2-L3 | 530 | 800    | 494 | Minor    |
| Nov 15, 18 15:34:20.036 | 620      | RMS Surge       | L3-L1 | 522 | 558    | 488 | Minor    |
| Nov 15, 18 15:34:20.036 | 621      | RMS Surge       | L2-L3 | 522 | 558    | 487 | Minor    |
| Nov 15, 18 19:27:32.269 | 673      | RMS Surge       | L3-L1 | 521 | 75     | 495 | Minor    |
| Nov 15, 18 19:27:32.269 | 674      | RMS Surge       | L2-L3 | 523 | 75     | 496 | Minor    |
| Nov 16, 18 12:44:10.194 | 880      | RMS Surge       | L3-L1 | 523 | 41     | 489 | Minor    |
| Nov 16, 18 12:44:10.194 | 881      | RMS Surge       | L2-L3 | 521 | 41     | 486 | Minor    |
| Nov 17, 18 04:23:50.444 | 1045     | RMS Surge       | L3-L1 | 530 | 120000 | 493 | Minor    |
| Nov 17, 18 04:23:50.444 | 1046     | RMS Surge       | L2-L3 | 529 | 120000 | 493 | Minor    |
| Nov 17, 18 04:56:53.761 | 1071     | RMS Surge       | L2-L3 | 519 | 120000 | 492 | Minor    |
| Nov 17, 18 04:56:53.769 | 1072     | RMS Surge       | L3-L1 | 519 | 120000 | 493 | Minor    |
| Nov 17, 18 05:08:21.828 | 1098     | RMS Surge       | L3-L1 | 518 | 34400  | 491 | Minor    |
| Nov 17, 18 05:08:21.828 | 1099     | RMS Surge       | L2-L3 | 518 | 34400  | 491 | Minor    |
| Nov 20, 18 00:15:43.461 | 1524     | RMS Surge       | L3-L1 | 529 | 5791   | 494 | Minor    |
| Nov 20, 18 00:15:43.461 | 1523     | RMS Surge       | L2-L3 | 530 | 5791   | 494 | Minor    |
| Nov 20, 18 08:12:55.261 | 1653     | RMS Surge       | L3-L1 | 518 | 7541   | 491 | Minor    |
| Nov 20, 18 08:12:55.261 | 1654     | RMS Surge       | L2-L3 | 517 | 7541   | 490 | Minor    |
| Nov 20, 18 08:26:40.061 | 1688     | RMS Surge       | L3-L1 | 518 | 1975   | 492 | Minor    |
| Nov 20, 18 08:26:40.061 | 1689     | RMS Surge       | L2-L3 | 517 | 1975   | 490 | Minor    |
| Nov 20, 18 09:01:08.553 | 1741     | RMS Surge       | L3-L1 | 518 | 8625   | 492 | Minor    |
| Nov 20, 18 09:01:08.553 | 1740     | RMS Surge       | L2-L3 | 517 | 8625   | 491 | Minor    |
| Nov 20, 18 10:26:40.078 | 1804     | RMS Surge       | L3-L1 | 518 | 19575  | 491 | Minor    |
| Nov 20, 18 10:26:40.078 | 1805     | RMS Surge       | L2-L3 | 516 | 19575  | 489 | Minor    |
| Nov 20, 18 16:52:38.328 | 2035     | RMS Surge       | L3-L1 | 515 | 120000 | 489 | Minor    |
| Nov 20, 18 16:52:38.328 | 2036     | RMS Surge       | L2-L3 | 515 | 120000 | 489 | Minor    |
| Nov 21, 18 00:08:35.394 | 2080     | RMS Surge       | L2-L3 | 519 | 8033   | 492 | Minor    |
| Nov 21, 18 00:08:35.402 | 2079     | RMS Surge       | L3-L1 | 519 | 8024   | 493 | Minor    |
| Nov 21, 18 02:24:38.219 | 2102     | RMS Surge       | L3-L1 | 520 | 51291  | 494 | Minor    |

## Parameters

| RMS Nominal        | RMS Re-Nominal                            | HF Transient                                                | HF Sensitivity | RMS Sag/Surge                                               | Line Impedance                              |
|--------------------|-------------------------------------------|-------------------------------------------------------------|----------------|-------------------------------------------------------------|---------------------------------------------|
| P1 = Nominal Volts | P1 = Prev Nom Volts<br>P2 = New Nom Volts | P1 = Peak Voltage<br>P2 = Duration uSec<br>P3 = Phase Angle | P1 = Sens Val  | P1 = Peak Voltage<br>P2 = Duration mSec<br>P3 = Nom Voltage | P1 = Impedance m $\Omega$<br>P2 = Nom Volts |

## Comments:

All events related to load changes and output impedance characteristics of power conditioner. Severe sags and impulses. Conditioner may be undersized, or incompatible with the connected load current profile.



## Detailed Event Log

12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

☒ Filter Good Events

11/14/2018 - 11/28/2018

| Date/Time               | Event ID | Event Type      | Chan  | P 1 | P 2    | P3  | Severity |
|-------------------------|----------|-----------------|-------|-----|--------|-----|----------|
| Nov 21, 18 02:24:38.219 | 2103     | RMS Surge       | L2-L3 | 520 | 51291  | 493 | Minor    |
| Nov 21, 18 03:15:13.511 | 2122     | RMS Surge       | L3-L1 | 520 | 24350  | 493 | Minor    |
| Nov 21, 18 03:15:13.511 | 2123     | RMS Surge       | L2-L3 | 519 | 24350  | 492 | Minor    |
| Nov 21, 18 03:20:03.319 | 2137     | RMS Sag         | L3-L1 | 492 | 120000 | 519 | Minor    |
| Nov 21, 18 03:20:03.319 | 2138     | RMS Sag         | L2-L3 | 491 | 120000 | 519 | Minor    |
| Nov 21, 18 03:33:42.478 | 2152     | RMS Surge       | L3-L1 | 520 | 6558   | 493 | Minor    |
| Nov 21, 18 03:33:42.478 | 2153     | RMS Surge       | L2-L3 | 519 | 6558   | 493 | Minor    |
| Nov 21, 18 05:37:55.878 | 2193     | RMS Surge       | L3-L1 | 517 | 91     | 491 | Minor    |
| Nov 21, 18 05:37:55.878 | 2194     | RMS Surge       | L2-L3 | 517 | 83     | 491 | Minor    |
| Nov 23, 18 00:25:36.769 | 2569     | RMS Surge       | L3-L1 | 522 | 1541   | 495 | Minor    |
| Nov 23, 18 00:25:36.769 | 2570     | RMS Surge       | L2-L3 | 521 | 1541   | 495 | Minor    |
| Nov 23, 18 19:25:14.478 | 2843     | RMS Surge       | L3-L1 | 522 | 1983   | 495 | Minor    |
| Nov 23, 18 19:25:14.478 | 2844     | RMS Surge       | L2-L3 | 522 | 1983   | 495 | Minor    |
| Nov 24, 18 02:34:44.161 | 2860     | RMS Surge       | L3-L1 | 521 | 25     | 495 | Minor    |
| Nov 24, 18 02:34:44.161 | 2861     | RMS Surge       | L2-L3 | 521 | 25     | 494 | Minor    |
| Nov 24, 18 04:43:02.086 | 2873     | RMS Surge       | L3-L1 | 519 | 25     | 493 | Minor    |
| Nov 24, 18 04:43:02.086 | 2874     | RMS Surge       | L2-L3 | 518 | 25     | 492 | Minor    |
| Nov 24, 18 06:31:50.286 | 2885     | RMS Surge       | L3-L1 | 518 | 216    | 492 | Minor    |
| Nov 24, 18 06:31:50.286 | 2886     | RMS Surge       | L2-L3 | 517 | 216    | 491 | Minor    |
| Nov 25, 18 00:45:41.453 | 2903     | RMS Surge       | L3-L1 | 521 | 216    | 495 | Minor    |
| Nov 25, 18 00:45:41.453 | 2904     | RMS Surge       | L2-L3 | 521 | 216    | 494 | Minor    |
| Nov 25, 18 06:33:46.419 | 2915     | RMS Surge       | L3-L1 | 519 | 491    | 493 | Minor    |
| Nov 25, 18 06:33:46.419 | 2914     | RMS Surge       | L2-L3 | 519 | 491    | 492 | Minor    |
| Nov 25, 18 18:32:31.511 | 2923     | RMS Surge       | L3-L1 | 529 | 50     | 494 | Minor    |
| Nov 25, 18 18:32:31.511 | 2924     | RMS Surge       | L2-L3 | 531 | 50     | 495 | Minor    |
| Nov 26, 18 23:28:46.269 | 3323     | RMS Surge       | L2-L3 | 518 | 16     | 492 | Minor    |
| Nov 26, 18 23:28:46.277 | 3322     | RMS Surge       | L3-L1 | 518 | 8      | 493 | Minor    |
| Nov 27, 18 13:36:18.969 | 3573     | RMS Surge       | L3-L1 | 523 | 700    | 488 | Minor    |
| Nov 27, 18 13:36:18.969 | 3574     | RMS Surge       | L2-L3 | 523 | 700    | 488 | Minor    |
| Nov 27, 18 15:10:20.078 | 3641     | RMS Surge       | L3-L1 | 520 | 558    | 486 | Minor    |
| Nov 27, 18 15:10:20.078 | 3642     | RMS Surge       | L2-L3 | 520 | 558    | 485 | Minor    |
| Nov 27, 18 15:11:48.428 | 3647     | RMS Surge       | L3-L1 | 512 | 841    | 486 | Minor    |
| Nov 27, 18 15:11:48.428 | 3646     | RMS Surge       | L2-L3 | 512 | 841    | 486 | Minor    |
| Nov 27, 18 20:22:47.386 | 3753     | RMS Surge       | L3-L1 | 520 | 458    | 494 | Minor    |
| Nov 27, 18 20:22:47.386 | 3754     | RMS Surge       | L2-L3 | 521 | 458    | 494 | Minor    |
| Nov 27, 18 22:08:59.469 | 3763     | RMS Surge       | L2-L3 | 519 | 8      | 494 | Minor    |
| Nov 28, 18 12:08:09     | 3969     | System Shutdown |       |     |        |     |          |

### Parameters

| RMS Nominal        | RMS Re-Nominal                            | HF Transient                                                | HF Sensitivity | RMS Sag/Surge                                               | Line Impedance                              |
|--------------------|-------------------------------------------|-------------------------------------------------------------|----------------|-------------------------------------------------------------|---------------------------------------------|
| P1 = Nominal Volts | P1 = Prev Nom Volts<br>P2 = New Nom Volts | P1 = Peak Voltage<br>P2 = Duration uSec<br>P3 = Phase Angle | P1 = Sens Val  | P1 = Peak Voltage<br>P2 = Duration mSec<br>P3 = Nom Voltage | P1 = Impedance m $\Omega$<br>P2 = Nom Volts |

### Comments:

All events related to load changes and output impedance characteristics of power conditioner. Severe sags and impulses. Conditioner may be undersized, or incompatible with the connected load current profile.




# RMS Voltage

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Nov 14, 18 18:18 - Nov 28, 18 12:03

12/14/2018

Max Lo/Hi: 482/532  
Avg Lo/Hi: 481/515  
Min Lo/Hi: 467/509






# RMS Voltage

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Nov 14, 18 18:18 - Nov 28, 18 12:03

12/14/2018

Max Lo/Hi: 277/332  
Avg Lo/Hi: 276/313  
Min Lo/Hi: 266/308








# Phase Voltage Imbalance

12/14/2018

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Nov 14, 18 18:18 - Nov 28, 18 12:03

Peak Imbalance: 2.88%






# RMS Current

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Nov 14, 18 18:18 - Nov 28, 18 12:03

12/14/2018

Max Lo/Hi: 3/95  
Avg Lo/Hi: 0.7/41  
Min Lo/Hi: 0.2/18






# RMS Current

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Nov 14, 18 18:18 - Nov 28, 18 12:03

12/14/2018

Max Lo/Hi: 4/59  
Avg Lo/Hi: 3/4  
Min Lo/Hi: 0.5/4






# AC Frequency

12/14/2018

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Nov 14, 18 18:18 - Nov 28, 18 12:03



## Comments:


Frequency 20 Cycle Average



# Harmonics

12/14/2018

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Jun 18, 18 12:19 - Jun 18, 18 15:58



## Comments:

Harmonics are available upon request. Please make sure to request them when you place your order so we can enable this feature on the monitor.




# THD Logs

12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

Nov 14, 18 18:18 - Nov 28, 18 12:03






# THD Logs

12/14/2018

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Nov 14, 18 18:18 - Nov 28, 18 12:03






# Temperature °F / Humidity %

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Nov 14, 18 18:13 - Nov 28, 18 12:03

12/14/2018

Temp Lo/Hi: 69/73  
Hum Lo/Hi: 24/58  
Max CPH T/H: 3/10







# Transient Scatter Plot



12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

11/14/2018 - 11/28/2018

☐ Filter Good Events





# Transient Scatter Plot



12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

11/14/2018 - 11/28/2018

☐ Filter Good Events





# Transient Scatter Plot



12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

11/14/2018 - 11/28/2018

☐ Filter Good Events





12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 992 - Nov 16, 18 15:32:17.170

Peak: -79

Duration: 391  $\mu$ S

Severity: Good



### Comments:

Load current is causing slight distortion of voltage waveform. This is normal system operation.



12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 1171 - Nov 18, 18 05:51:35.856

Peak: -111

Duration: 846  $\mu$ S

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.



12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 1178 - Nov 19, 18 05:51:35.956

Peak: -102

Duration: 911  $\mu$ s

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.



12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 1585 - Nov 20, 18 05:51:35.413

Peak: -103

Duration: 1628  $\mu$ s

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.



12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 2562 - Nov 22, 18 05:51:35.011

Peak: 111

Duration: 1042  $\mu$ S

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.





12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 2582 - Nov 23, 18 05:51:34.560

Peak: -121

Duration: 391  $\mu$ s

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.



12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 2877 - Nov 24, 18 05:51:34.058

Peak: -133

Duration: 1432  $\mu$ s

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.



12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 2912 - Nov 25, 18 05:51:33.569

Peak: -109

Duration: 391  $\mu$ s

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.



12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 3328 - Nov 27, 18 05:51:32.657

Peak: 109

Duration: 1042  $\mu$ S

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.



12/14/2018

## Transient

Site: 31098



Rx Monitoring Services, Inc. Demo

Event 3793 - Nov 28, 18 05:51:27.098

Peak: -111

Duration: 2148  $\mu$ s

Severity: Good



### Comments:

Possible Power Factor Capacitor switching or switch-on of another load.




# Snapshot

Site: 31098

Rx Monitoring Services, Inc. Demo  
Event 178 - Wednesday, Nov 14, 2018 18:08:19

12/14/2018

Volts Angle: 121.1  
Phase Seq: CW(ABC)



## Comments:

AC voltage during normal operating conditions. Notice how the Phase-to-Phase voltage is peaked but the Phase-to-Ground is flat-topped. This is an indication that the ground reference could be a problem.



# Snapshot


Site: 31098

Rx Monitoring Services, Inc. Demo

Event 1283 - Monday, Nov 19, 2018 10:00:00

12/14/2018

Volts Angle: 121.1  
Phase Seq: CW(ABC)



## Comments:

AC voltage during normal operating conditions. Notice how the Phase-to-Phase voltage is peaked but the Phase-to-Ground is flat-topped. This is an indication that the ground reference could be a problem.




# Snapshot

Site: 31098

Rx Monitoring Services, Inc. Demo  
Event 2724 - Friday, Nov 23, 2018 10:00:00

12/14/2018

Volts Angle: 121.0  
Phase Seq: CW(ABC)



## Comments:

AC voltage and current during normal operating conditions.





# Snapshot


Site: 31098

Rx Monitoring Services, Inc. Demo

Event 3454 - Tuesday, Nov 27, 2018 10:00:00

12/14/2018

Volts Angle: 120.8  
Phase Seq: CW(ABC)



## Comments:


AC voltage and current during normal operating conditions.



# Snapshot Harmonics

12/14/2018

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Event 178 - Wednesday, Nov 14, 2018 18:08:19






# Snapshot Harmonics

12/14/2018

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Event 3454 - Tuesday, Nov 27, 2018 10:00:00








# V & I + Voltage Deviation

12/14/2018

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Event 290 - Wednesday, Nov 14, 2018 20:09:00








# V & I + Voltage Deviation

12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

Event 313 - Thursday, Nov 15, 2018 02:59:00








# V & I + Voltage Deviation

12/14/2018

Site: 31098  
Rx Monitoring Services, Inc. Demo  
Event 617 - Thursday, Nov 15, 2018 15:34:20








# V & I + Voltage Deviation

12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

Event 876 - Friday, Nov 16, 2018 12:44:10










# V & I + Voltage Deviation

12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

Event 1038 - Saturday, Nov 17, 2018 04:23:50










# V & I + Voltage Deviation

12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

Event 1533 - Tuesday, Nov 20, 2018 00:24:59





# V & I + Voltage Deviation

12/14/2018

Site: 31098

Rx Monitoring Services, Inc. Demo

Event 1670 - Tuesday, Nov 20, 2018 08:16:46

